

Transmittal

April 30, 2024

to: Bidders from: Amanda Matlock, CCS, CDT
 company: _____ title: Procurement Manager
 address: _____ tel: 843-735-5154

subject: Addendum Number 2
 Repair/Replace Roofing Systems – Grand Strand Campus
 Owner Project Number: H59-6229-PD
 BEE Project Number: 23010C

The following items are attached and include a total of 2 pages including transmittal:

ITEM #	DATE	DESCRIPTION
I.	April 30, 2024	Addendum Number 2 (1 Page)

If you have any questions or comments, please do not hesitate to contact me.

delivered by: www.hgtc.edu/purchasing

Addendum Number 2

April 30, 2024

Repair/Replace Roofing Systems – Grand Strand Campus

Owner Project Number: H59-6229-PD

Prepared by:

The Building Envelope Enclosure Group

1226 Yeamans Hall Road, Suite C

Hanahan, SC 29410

To Bidders:

This Addendum forms a part of the Contract Documents and modifies the original Procurement Documents as noted below. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of 1 page and the attachments listed.

Changes to Prior Addenda:

1. There are no changes to Addendum Number 1 dated April 24, 2024.

Changes to Procurement Requirements:

2. None.

Changes to Contracting Requirements:

3. None.

Changes to Specifications:

4. None.

Changes to Drawings:

5. None.

Clarifications:

6. Specific to Building 300, see Sheet R205, Note 2 and Detail 20/R404. New hat channels/metal panels are not required.
7. For roof areas F & G on Building 300: New wood curb and transition flashing to reuse existing gravity vent hoods. Prepare, prime and two coats of paint for existing vent hoods.
8. For Areas B1 and D2 (areas with the large units) at Building 1000, Sheets R303 and R309 show existing assembly. New assembly shall be mechanically fastened base sheet, 1.0 ISO and 1/2" coverboard, and roof system.

End of Addendum Number 2